

## City of Las Vegas Code and Interpretation

**AMEND:** 12

**DATE:** December 19, 2008

**CODE:**      2006 IBC ☒      2005 NEC ☒      Local Amendments ☐  
                 2006 IRC ☐      2006 UMC ☐      POOL CODE ☐  
                 2006 IECC ☐      2006 UPC ☐      MISC. ☐

**CODE SECTION:** Southern Nevada Amendments to the NEC 700.16

**TOPIC:** No emergency light required in a single user restroom.

**PURPOSE/REASON:** Provide some form of emergency lighting to illuminate the area for safe egress. A minimum of 1 foot candle would not be required in a single user restroom.

**INTERPRETATION:** Submit proposal to IBC code committee

Approved: Chris Knight, CBO